



333 Main Street NW
P.O. Box 388
Elk River, MN 55330
Phone: 763-441-7509
Fax: 763-441-9176

DRINKING WATER LABORATORY TEST REPORT

Last Name: FRADETTE
First Name: DALE
Address: 18467 VINELAND RD
City: ONAMIA
State: MN **Zip Code:** 56359
County:
Legal:

File #: 100181
Date/Time in Lab: 8/8/2025 12:32 PM
Unique Well #:
Drillers #:

Ordered By: MAMA T'S SEPTIC SERVICE
Sampled From: Outside Tap
Sampled By: TRACI BECKSTROM
Date/Time Sampled: 08/07/2025 1945
Reason For Test: Coliform + Nitrate
Sample Temp: 11.5 ° C
Received on Ice: Yes

<u>ANALYTE & METHOD</u>	<u>DATE & TIME OF ANALYSIS</u>	<u>MAXIMUM CONTAMINATION LEVEL (EPA)</u>	<u>TEST RESULTS</u>
Coliform Bacteria (SM 9223 B)	08/08/2025 1400	Negative	Negative
Nitrate (EPA 353.2 Rev 2.0)	08/08/2025 1330	10.0 ppm	< 0.5 ppm

This sample **DOES** meet EPA guidelines for safe drinking water for the Analytes tested.

Notes:

The test results are only indicative of the sample tested from the sample point on the date collected.
This report must not be reproduced, except in full, without the written approval from Water Laboratories, Inc.
Minnesota Certification# 027-141-110, Wisconsin Certification #399044470 (for compliance with NR812)

Water Laboratories, Inc.

By: 

Date: 08/11/2025

Received By TJ Entered By EK Edited By TJ

Amount Billed:

Date Paid: 08/08/2025

Amount Paid: