



333 Main Street NW
 P.O. Box 388
 Elk River, MN 55330
 Phone: 763-441-7509
 Fax: 763-441-9176

DRINKING WATER LABORATORY TEST REPORT

Last Name: KELZENBERG **File #:** 100488
First Name: LESLIE **Date/Time in Lab:** 8/19/2025 12:13 PM
Address: 5235 313TH AVE NW
City: CAMBRIDGE **Unique Well #:**
State: MN **Zip Code:** 55008 **Drillers #:**
County:
Legal:

Ordered By: LESLIE KELZENBERG **Sampled From:** Outside Tap
Sampled By: Kevin Kloepfner **Date/Time Sampled:** 08/19/2025 1005
Reason For Test: Coliform + Nitrate **Sample Temp:** 17.3 ° C
Received on Ice: Yes

<u>ANALYTE & METHOD</u>	<u>DATE & TIME OF ANALYSIS</u>	<u>MAXIMUM CONTAMINATION LEVEL (EPA)</u>	<u>TEST RESULTS</u>
Coliform Bacteria (SM 9223 B)	08/19/2025 1220	Negative	Negative
Nitrate (EPA 353.2 Rev 2.0)	08/19/2025 1429	10.0 ppm	< 0.5 ppm

This sample meet EPA guidelines for safe drinking water for the Analytes tested.

Notes:

The test results are only indicative of the sample tested from the sample point on the date collected.
 This report must not be reproduced, except in full, without the written approval from Water Laboratories, Inc.
 Minnesota Certification# 027-141-110, Wisconsin Certification #399044470 (for compliance with NR812)

Water Laboratories, Inc.

By: 

Date: 08/20/2025

Received By TJ Entered By TJ Edited By TJ

Amount Billed: \$173.00
Date Paid: 08/20/2025
Amount Paid: \$173.00